

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing 325603 Zhejiang
China

Name and address of the manufacturer

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing 325603 Zhejiang
China

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing 325603 Zhejiang
China

Ratings and principal characteristics

1P, 2P, 3P, 4P
Ue: 230 / 400 Vac for 1P, 400 Vac for 2P, 3P and 4P
In: 1, 2, 3, 4, 5, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63 A
B, C and D type, 50 / 60 Hz, All poles are protected
Ics = 7,5 kA, Icn = Icn1 = 10 kA
The grid distance "a": 45 mm

Trademark (if any)

GACIA

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PB8H, PB8HN, PB8HQ, PB8H2, PB8N, PB8NN, PB8NQ, PB8N2, PB8LN, M80H, M100, M80,
N8BH, VB8H, DB10HAdditional information (if necessary may also be
reported on page 2)☐ Additional information on page 2Energy limiting class 3 for B and C type according to EN 60898-1. This certificate replaces CB NL-
38070 issued on 2015-11-20. The tests were performed in 2008, 2011, 2013, 2015 and 2020.A sample of the product was tested and found
to be in conformity with

IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

As shown in the Test Report Ref. No. which
forms part of this Certificate

3317040.50, 3307943.50, 3305490.50, 3303230.50, 3302398.50, W0807018.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands