

ATTESTATION OF CONFORMITY

Issued to: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China

For the product: Residual current operated circuit-breakers without integral overcurrent protection
(RCCB)

Trade name: GACIA

Type/Model: PR8HM, PR8HE, PR8NM, PR8NE, R80M, R80M-R, R80E

Ratings: 1P+N, 3P+N, 230 Vac (1P+N), 400 Vac (3P+N), 50 / 60 Hz
I Δ n: 100, 300 mA for all In, 30 mA for In: 16, 25, 40, 63 A
In: 16, 25, 40, 63, 80, 100 A, type A and AC, without time delay,
I Δ m = I Δ n = 1 kA, I Δ c = I Δ c = 10 kA, the grid distance "a" = 50 mm

Manufactured by: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China

Subject: Type Test

Requirements: EN 61008-1:2012+A1:2014+A2:2014+A11:2015+A12:2017, EN 61008-2-1:1994+A11:1998, IEC 61008-1:2010+A1:2012+A2:2013, IEC 61008-2-1:1990

Remark: This Attestation replaces AoC no. 2153046.01A issued on 2012-06-13.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports no. 3317036.50 issued on 2020-08-19, 3305104.50 issued on 2013-11-22 and 3302524.50 issued on 2012-06-13.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 27 August 2020

Number: 3317036.01A

DEKRA Testing Services (Zhejiang) Co., L td.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

