

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang,
China

Name and address of the manufacturer

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang,
China

Name and address of the factory

Note: When more than one factory, please report on page 2

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang,
China

☐ Additional information on page 2

Ratings and principal characteristics

1P+N, 50 / 60 Hz
Ue: 240 Vac
In= 6, 10, 16, 20, 25, 32, 40 A, type B and C
Ics = Icn = 6 kA, the grid distance "a": 45 mm

Trademark / Brand (if any)

GACIA

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

M100N, M80N, PN8H, PN8HQ, PN8L, PN8LQ, PN8N and PN8NQ

Additional information (if necessary may also be reported on page 2)

Energy limiting class 3 according to EN 60898-1:2019

This certificate replaces CB NL-34697 issued on 2015-02-04.

The tests were performed in 2009 to 2010, 2015 and 2022.

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

3301074.50, 3303233.50, 3307344.50 and 3325601.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2022-10-05

Signature: H.L. Schendstok