

CERTIFICATE

Issued to:

Applicant:

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone,
Beibaixiang Town, Yueqing
325603 Zhejiang, China

Licensee:

GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone,
Beibaixiang Town, Yueqing
325603 Zhejiang, China

Product : Circuit-breakers for overcurrent protection
Trade name(s) : GACIA
Type(s)/model(s) : M100N, M80N, PN8H, PN8HQ, PN8L, PN8LQ, PN8N and PN8NQ

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 60898-1:2019, IEC 60898-1:2015 and IEC 60898-1:2015/A1:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2157361


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 8 October 2022 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-125375

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



R Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Circuit-breakers for overcurrent protection
Trade name(s)	: GACIA
Type(s)/model(s)	: M100N, M80N, PN8H, PN8HQ, PN8L, PN8LQ, PN8N and PN8NQ
Rated current (In)	: 6, 10, 16, 20, 25, 32, 40 A
Range of instantaneous tripping current	: B and C
Number of poles	: 1P+N
Rated voltage (Ue)	: 240 Vac
Rated frequency	: 50 / 60 Hz
Rated short-circuit capacity (Icn)	: 6000 A
Rated making and breaking capacity of individual pole (Icn1)	: 6000 A
Rated service short-circuit capacity (Ics)	: 6000 A
Energy limiting class	: 3
Method of mounting	: Flush-type, for mounting on top hat rail 35 mm (EN 50022)
Degree of protection against moisture	: IP20
Connection	: screw type terminals
Markings	: trade name, type designation and electrical ratings are indicated on the body
Grid distance "a" (grid)	: 45 mm

TESTS**Test requirements**

EN 60898-1:2019

IEC 60898-1:2015

IEC 60898-1:2015/A1:2019

Test result

The test results are laid down in DEKRA test file 332560100.

Additional information

The referred test reports are 3301074.50, 3303233.50, 3307344.50 and 3325601.50.

This certificate replaces certificate No. 3307344.01 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

GACIA ELECTRICAL APPLIANCE CO., LTD.

No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China