

ATTESTATION OF CONFORMITY

Issued to: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing 325603
Zhejiang, China

For the product: Circuit breakers for overcurrent protection

Trade name: GACIA

Type/Model: M100N, M80N, PN8H, PN8HQ, PN8L, PN8LQ, PN8N and PN8NQ

Ratings: 1P+N, 50 / 60 Hz
Ue: 240 Vac
In= 6, 10, 16, 20, 25, 32, 40 A, type B and C
Ics = Icn = 6 kA, the grid distance "a": 45 mm
Energy limiting class 3

Manufactured by: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing 325603
Zhejiang, China

Subject: Type Test

Requirements: EN 60898-1:2019, IEC 60898-1:2015, IEC 60898-1:2015/A1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no. 3301074.50 issued on 2010-03-09, 3303233.50 issued on 2012-05-02, 3307344.50 issued on 2015-02-04 and 3325601.50 issued on 2022-09-19.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 10 October 2022

Number: 3325601.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

